



ELECTRONICALLY FILED WITH RCA

March 12, 2024

Regulatory Commission of Alaska
701 W. 8th Avenue, Suite 300
Anchorage, AK 99501

Subject: Tariff Advice No. 430-121; Annual Update to the G&T Loss Factor

Commissioners:

The tariff filing described below is hereby transmitted to you for filing in compliance with the Alaska Public Utilities Commission Act and Sections 3 AAC 48.200 - 3 AAC 48.420 of the Alaska Administrative Code. The purpose of this filing is to update Chugach Electric Association, Inc.'s (Chugach) generation and transmission (G&T) loss factor based on calendar-year 2023 operating results. The following tariff sheets are submitted for approval:

TARIFF SHEET NUMBER <u>ORIGINAL</u>	CANCELS SHEET NUMBER <u>REVISED</u>	SCHEDULE OR <u>RULE NUMBER</u>
122	3 rd Revision	122
123	3 rd Revision	2 nd Revision

This filing is not for a new service, will not result in the termination of an existing service, conflict with any other schedule or rate contained in Chugach's operating tariff, or in any other way adversely impact customers or the public. Chugach provides electric service to approximately 93,000 retail members with 113,000 retail metered locations and wholesale customer Seward Electric System (Seward). Chugach is projecting annual revenues of approximately \$357.1 million for calendar-year 2024.

Summary

The annual update of the G&T loss factors is calculated at delivery and generation levels on a percentage basis. These percentages are used for the allocation of system costs between G&T and Distribution functions in Chugach's cost of service studies, cost of power rate adjustment processes, and the determination of losses applied to transmission wheeling transactions.

The updated G&T loss factor proposed in this filing is 1.615 percent as measured at generation. Prior to Chugach's acquisition of Municipal Light & Power (ML&P), Chugach's average G&T loss factor was approximately 2.5 percent. Chugach's post-acquisition system includes the addition of nearby generation facilities and an expanded customer base that is concentrated in the Anchorage downtown area. These system changes have contributed to the reduction in the calculated losses. The proposed G&T loss factor reflects the updated measurement points and

Chugach Electric Association, Inc.

5601 Electron Drive, P.O. Box 196300, Anchorage, Alaska 99519-6300 • (907) 563-7494 Fax (907) 562-0027 • (800) 478-7494
www.chugachelectric.com • info@chugachelectric.com

transmission system boundaries resulting from Chugach's acquisition of ML&P, without changing the underlying methodology that has been approved for the calculation of the G&T loss factor. Consistent with prior year calculations, losses from Bradley Lake to Quartz Creek are not included in the loss factor calculation. If approved, the updated loss factor will increase Seward's G&T cost responsibility by approximately \$1,002 and decrease the G&T cost responsibility to Chugach's retail members by an equivalent amount. In this update, there is no rate impact on third party transmission customers because Chugach is not changing its transmission wheeling rates.

Compliance with U-99-106(12)

The G&T loss factor was calculated in accordance with the methodology contained in the stipulation between Chugach, Homer Electric Association, Inc. (HEA) and Matanuska Electric Association, Inc. (MEA) and accepted by the Commission in Order U-99-106(12). Pursuant to this order, preliminary 2023 test year loss factor calculations and supporting work papers were provided to HEA, MEA and the Regulatory Affairs and Public Advocacy Section of the Attorney General's Office for review and comment. Preliminary calculations and work papers were also provided to Golden Valley Electric Association, Inc. (GVEA), and Seward.

A meeting was held on February 22, 2024, to review the calculations and discuss preliminary results. The meeting was attended by representatives from Chugach, GVEA, MEA, and the Regulatory Affairs and Public Advocacy Section of the Attorney General's Office. The discussion resulted in no changes to the preliminary results and Chugach is not aware of any outstanding issues associated with this year's update.

Description of Tariff Sheets Changes and Supporting Attachments

Tariff Sheet No. 122: Updated to delete IGT Power Plant, IGT station service and Teeland 34.5 kV Breaker 332 from this sheet.

Tariff Sheet No. 123: Updated to include Chugach's 2023 energy flows and calculated losses. The proposed Chugach G&T loss factors are measured at both generation and delivery.


Attachment I: Provides the calculations for Chugach's electrical system monthly G&T loss factors at Delivery and generation. Loss calculations in this attachment are based on specific boundary points where energy enters or leaves the G&T system and are adjusted for house power and transformer losses.

Attachment II: Provides calculated transformer losses for the transformers that do not have a low voltage side measurement point. In accordance with the Black and Veatch G&T Line Loss Study, for the metering points where only low voltage side measurements are available, the calculated transformer losses are removed from the G&T loss calculation and added into the distribution loss calculation. Four of the North District transformers provided on this attachment are still undergoing IEEE C57 standard testing and the results are expected to be available in a future update.

Please contact Jean Kornmuller, Sr. Manager, Regulatory Affairs at (907) 762-4184 or Jean_Kornmuller@chugachelectric.com if additional information is needed.

Sincerely,

CHUGACH ELECTRIC ASSOCIATION, INC.



Arthur W. Miller
Chief Executive Officer
P.O. Box 196300
Anchorage, Alaska 99519-6300
Telephone: 907-762-4758
Arthur_Miller@chugachelectric.com

Attachments

cc: K. Sorenson, City of Seward (electronic)
D. Heckman, Golden Valley Electric Association, Inc. (electronic)
T. Clark, Matanuska Electric Association, Inc. (electronic)
J. Draves, Homer Electric Association, Inc. (electronic)
J. Waller, Attorney General of Regulatory Affairs & Public Advocacy (electronic)

RCA NO.: 1213rd RevisionSheet No. 122

Canceling

2nd RevisionSheet No. 122

Chugach Electric Association, Inc.

**CALCULATION OF CHUGACH G&T LOSSES
2023 Test Year**

Description	Q1-23	Q2-23	Q3-23	Q4-23	Total
<u>Energy Entering System</u>					
Beluga Power Plant	182.3	1,460.9	1,738.5	2,849.1	6,230.8
Fire Island Wind (IGT Bkr 532)	12,704.0	14,041.5	7,808.2	12,814.1	47,367.8
Southcentral Power Project	316,817.3	255,860.0	128,861.9	229,106.2	930,645.3
Plant 1	7,890.2	5,558.0	5,920.4	20,906.7	40,275.4
Plant 2	1,259.4	3,568.9	2,173.0	41,349.2	48,350.5
Plant 2A	230,513.6	155,609.5	239,112.0	228,651.0	853,886.0
Quartz Creek Substation	114,595.3	53,743.8	80,473.5	77,967.2	326,779.8
Teeland Substation	57,663.9	35,882.0	60,656.9	105,162.1	259,364.9
Plant 2 230 Yard	0.0	39,644.3	45,097.6	34,658.8	119,400.7
Eklutna Substation	5,902.1	0.0	2,135.2	0.0	8,037.3
International Substation	0.0	0.0	0.0	0.0	0.0
Cooper Lake Power Plant	11,959.3	10,098.8	16,998.3	8,803.9	47,860.4
Eklutna Hydro Electric Power Plant	31,555.9	43,819.7	65,968.5	58,378.5	199,722.5
Total Energy Entering System	791,043.2	619,287.4	656,944.0	820,646.8	2,887,921.3
<u>Energy Leaving System</u>					
Quartz Creek Substation	14,959.6	14,676.2	15,431.8	13,680.4	58,748.0
Daves Creek Substation	36,980.0	43,334.7	67,455.2	57,746.6	205,516.6
Eklutna Substation	166,674.8	81,627.7	95,951.7	200,768.7	545,022.9
Plant 2 230 Yard	23,226.0	0.0	0.0	0.0	23,226.0
International Substation	104.9	100.9	105.0	107.2	418.0
Power Plant Station Service Totals	20,538.3	16,075.1	15,615.2	18,162.6	70,391.2
South - Distribution Substation Deliveries	288,524.1	248,666.3	246,784.5	292,597.2	1,076,572.2
North - Distribution Substation Deliveries	228,636.5	207,377.6	207,939.1	228,213.1	872,166.3
Total Energy Leaving System	779,644.1	611,858.5	649,282.7	811,275.8	2,852,061.1
Gross Energy Losses	11,399.0	7,428.9	7,661.3	9,371.0	35,860.2
Less Transformer Losses	1,591.4	1,591.4	1,591.4	1,591.4	6,365.5
Net G&T Losses	9,807.7	5,837.5	6,069.9	7,779.6	29,494.7

Tariff Advice No. 430-121

Issued by:

Chugach Electric Association, Inc.
P.O. Box 196300 Anchorage, Alaska 99519-6300

Effective: May 1, 2024

RCA NO.: 1213rd RevisionSheet No. 123

Canceling

2nd RevisionSheet No. 123

Chugach Electric Association, Inc.

CALCULATION OF CHUGACH G&T LOSSES
2023 Test Year¹

Description	Q1-23	Q2-23	Q3-23	Q4-23	Total
Chugach Retail Distribution Losses					
Retail Receipts at Transmission Substation	517,160.6	456,043.9	454,723.7	520,810.3	1,948,738.4
Less: Chugach House Power	2,696.9	1,470.9	1,278.2	1,501.9	6,947.9
Net Receipts	514,463.7	454,573.0	453,445.5	519,308.4	1,941,790.6
Retail Sales at Delivery	501,145.8	442,110.6	440,614.5	507,217.3	1,891,088.2
Losses	13,317.9	12,462.4	12,831.0	12,091.1	50,702.4
Add: 1/2 House Power	1,348.4	735.5	639.1	751.0	3,473.9
Adj. Retail Dist. Losses	14,666.4	13,197.8	13,470.1	12,842.0	54,176.3
At Delivery	2.927%	2.985%	3.057%	2.532%	2.865%
At Transmission Substation	2.851%	2.903%	2.971%	2.473%	2.790%

Adjustment of G&T Losses for House Power

G&T Deliveries	532,212.0	470,809.0	470,228.8	534,578.0	2,007,827.9
Net G&T Losses	9,807.7	5,837.5	6,069.9	7,779.6	29,494.7
Add: 1/2 House Power	1,348.4	735.5	639.1	751.0	3,473.9
Adjusted G&T Losses	11,156.1	6,573.0	6,709.0	8,530.6	32,968.6
At Delivery	2.096%	1.396%	1.427%	1.596%	1.642% R
At Generation	2.053%	1.377%	1.407%	1.571%	1.615% R

¹ G&T loss factor effective for the allocation of actual costs beginning January 1, 2024.

Tariff Advice No. 430-121

Issued by:

Chugach Electric Association, Inc.
 P.O. Box 196300 Anchorage, Alaska 99519-6300

Effective: May 1, 2024

Attachment I

Chugach Electric Association, Inc.
 Monthly G&T Line Loss Calculation; U-99-106
 In Accordance with Section 7, April 12, 2002
 Tariff Advice Nos. 552-8 / 430-121

Values used in calculation not rounded; data formatted to show the nearest tenth of a MWh.

Measurement Point	Source ¹	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Total 2023
<u>Energy Entering System</u>														
Beluga Power Plant														
Beluga 13.8 BKR 126	S	0.0	0.0	0.0	153.4	0.0	0.0	125.2	0.0	0.0	60.3	0.0	0.0	338.9
Beluga 13.8 BKR 226	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Beluga 13.8 BKR 326	S	0.0	182.3	0.0	0.0	486.9	0.0	0.0	422.8	444.0	0.0	548.9	2,068.6	4,153.6
Beluga 13.8 BKR 526	S	0.0	0.0	0.0	80.6	0.0	313.6	197.8	258.9	0.0	33.4	0.0	0.0	884.2
Beluga 13.8 BKR 626	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Beluga 13.8 BKR 726	S	0.0	0.0	0.0	210.6	0.0	215.8	0.0	0.0	289.8	137.8	0.0	0.0	854.1
Beluga 13.8 BKR 826	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total Beluga Power Plant		0.0	182.3	0.0	444.5	486.9	529.4	323.0	681.7	733.8	231.5	548.9	2,068.6	6,230.8
Fire Island Wind														
Fire Island Wind (FISS Bkr 532)	M	5,263.0	2,664.3	4,776.7	3,984.3	5,446.2	4,611.0	2,062.3	2,940.0	2,805.9	3,361.0	4,949.1	4,504.1	47,367.8
Total Fire Island Wind		5,263.0	2,664.3	4,776.7	3,984.3	5,446.2	4,611.0	2,062.3	2,940.0	2,805.9	3,361.0	4,949.1	4,504.1	47,367.8
SPP														
Unit No. 1 / 10	S	25,207.0	24,062.7	21,737.3	21,346.4	25,014.4	2,466.5	0.0	0.0	0.0	0.0	0.0	0.0	119,834.3
Unit No. 2 / 11	S	29,236.7	27,824.6	26,956.5	27,884.9	29,302.6	5,754.1	19,715.1	20,234.7	21,981.7	14,737.3	29,766.0	33,362.0	286,756.1
Unit No. 3 / 12	S	28,065.7	27,412.2	20,481.0	25,983.2	29,089.7	15,932.7	13,099.8	12,042.6	6,652.5	14,140.3	29,047.6	32,166.1	254,113.5
Unit No. 4 / 13	S	29,159.8	27,433.8	29,239.9	25,422.7	29,027.2	18,635.6	19,102.9	12,548.3	3,484.3	19,885.0	23,771.9	32,230.0	269,941.5
Total SPP		111,669.2	106,733.3	98,414.7	100,637.3	112,433.9	42,788.8	51,917.8	44,825.7	32,118.4	48,762.6	82,585.6	97,758.0	930,645.3
Plant 1														
Unit No. 3	S	720.4	5,458.4	1,711.5	573.9	3,783.1	1,201.0	2,629.1	656.7	2,634.7	15,356.7	4,401.8	1,148.1	40,275.4
Unit No. 4	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total Plant 1		720.4	5,458.4	1,711.5	573.9	3,783.1	1,201.0	2,629.1	656.7	2,634.7	15,356.7	4,401.8	1,148.1	40,275.4
Plant 2														
Unit No. 7	S	427.5	585.4	81.7	79.2	698.4	2,709.7	1,756.1	170.9	91.6	6,722.4	15,403.1	18,204.0	46,930.1
Unit No. 8	S	0.0	0.0	164.7	0.0	0.0	81.6	154.3	0.0	0.0	772.3	247.5	0.0	1,420.4
Total Plant 2		427.5	585.4	246.5	79.2	698.4	2,791.3	1,910.5	170.9	91.6	7,494.7	15,650.6	18,204.0	48,350.5
Plant 2A														
Unit No. 9	S	29,041.1	30,672.8	33,303.4	24,664.8	16,276.4	26,981.5	32,565.7	30,918.1	30,860.9	24,947.7	26,896.3	34,903.1	342,031.7
Unit No. 10	S	26,780.3	28,042.5	28,045.1	22,419.7	7,729.4	23,387.5	29,837.6	27,955.7	28,735.3	24,251.7	32,341.9	33,656.2	313,182.8
Unit No. 11 (Steam)	S	18,367.7	17,803.5	18,457.2	14,651.0	3,042.4	16,456.9	19,955.3	19,368.9	18,914.6	14,414.6	17,311.7	19,927.7	198,671.5
Total Plant 2A		74,189.0	76,518.9	79,805.7	61,735.5	27,048.2	66,825.9	82,358.5	78,242.7	78,510.8	63,614.1	76,549.8	88,487.1	853,886.0
Cooper Lake Power Plant														
Chugach CLPP	S	5,279.9	6,658.4	21.0	37.0	2,188.8	7,873.0	8,509.7	4,648.3	3,840.4	5,771.0	2,826.5	206.5	47,860.4
Total Cooper Lake Power Plant		5,279.9	6,658.4	21.0	37.0	2,188.8	7,873.0	8,509.7	4,648.3	3,840.4	5,771.0	2,826.5	206.5	47,860.4
Eklutna Hydro Electric Power Plant														
Eklutna Hydro	S	9,094.9	11,707.0	10,754.0	16,970.5	13,487.9	13,361.3	10,489.1	26,870.9	28,608.5	25,326.2	16,323.6	16,728.7	199,722.5
Total Eklutna Hydro Electric Power Plant		9,094.9	11,707.0	10,754.0	16,970.5	13,487.9	13,361.3	10,489.1	26,870.9	28,608.5	25,326.2	16,323.6	16,728.7	199,722.5
Total Energy Entering System		258,367.3	278,869.2	253,806.7	221,479.1	210,933.2	186,875.0	217,516.1	223,248.4	216,179.5	245,080.5	271,210.8	304,355.5	2,887,921.3

Energy Entering or Leaving System

International Substation														
INSS BKR 532 (MSESS)	S	35.5	33.0	36.4	34.7	35.0	31.1	35.8	35.0	34.2	36.2	35.0	36.0	418.0
Total International Substation Entering the G&T System		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total International Substation Leaving the G&T System		35.5	33.0	36.4	34.7	35.0	31.1	35.8	35.0	34.2	36.2	35.0	36.0	418.0

Attachment I

Page 1 of 4

Chugach Electric Association, Inc.
 Monthly G&T Line Loss Calculation; U-99-106
 In Accordance with Section 7, April 12, 2002
 Tariff Advice Nos. 552-8 / 430-121

Values used in calculation not rounded; data formatted to show the nearest tenth of a MWh.

Measurement Point	Source ¹	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Total 2023
Quartz Creek Substation														
Soldotna 115 SldQtzLn	S	(39,167.5)	(37,174.2)	(38,253.6)	(20,097.8)	(9,205.3)	(24,440.7)	(28,468.6)	(25,441.4)	(26,563.5)	(26,940.0)	(23,381.8)	(27,645.4)	(326,779.8)
Total Quartz Creek Substation Entering the G&T System		39,167.5	37,174.2	38,253.6	20,097.8	9,205.3	24,440.7	28,468.6	25,441.4	26,563.5	26,940.0	23,381.8	27,645.4	326,779.8
Total Quartz Creek Substation Leaving the G&T System		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Plant 2 Yard														
Plant 2 Bus M EklNorth MW (MEA Tie)	S	7,184.8	12,338.7	3,702.5	(4,905.9)	(20,860.2)	(13,878.3)	(5,733.8)	(19,638.2)	(19,725.6)	(20,059.8)	(7,873.8)	(6,725.3)	(96,174.7)
Total Plant 2 Yard Entering the G&T System		0.0	0.0	0.0	4,905.9	20,860.2	13,878.3	5,733.8	19,638.2	19,725.6	20,059.8	7,873.8	6,725.3	119,400.7
Total Plant 2 Yard Leaving the G&T System		7,184.8	12,338.7	3,702.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	23,226.0
Eklutna Substation														
Eklutna BKR 362 MW	S	11,840.8	12,563.9	12,575.4	12,764.3	12,775.5	12,218.1	12,488.8	17,279.7	18,080.3	18,918.8	8,141.8	2,093.3	151,740.4
Eklutna BKR 462 MW	S	(2,903.2)	(1,016.6)	(1,982.3)	4,025.4	567.7	983.8	(2,135.2)	9,348.3	10,258.2	6,156.9	7,999.1	14,436.7	45,738.9
Total Eklutna Substation Entering the G&T System		2,903.2	1,016.6	1,982.3	0.0	0.0	0.0	2,135.2	0.0	0.0	0.0	0.0	0.0	8,037.3
Total Eklutna Substation Leaving the G&T System		11,840.8	12,563.9	12,575.4	16,789.7	13,343.1	13,201.9	12,488.8	26,628.0	28,338.5	25,075.7	16,141.0	16,530.0	205,516.6
Teeland Substation														
Teeland 115 kV T1	S	23,587.9	34,642.3	24,192.4	17,018.7	12,840.4	5,400.4	13,855.9	6,100.8	5,110.5	10,790.4	26,666.4	33,061.7	213,267.7
Teeland 115 1452 (T3)	S	9,652.8	30,170.4	17,840.7	12,013.2	15,294.4	8,574.4	20,978.6	19,131.9	20,546.4	28,163.0	36,119.4	40,879.7	259,364.9
Teeland 138 BKR 538 (T2)	S	18,395.7	40,911.2	24,945.3	16,804.9	19,267.8	10,295.5	25,784.2	21,881.5	23,218.9	32,828.5	45,361.9	52,059.8	331,755.2
Total Teeland Substation Entering the G&T System		9,652.8	30,170.4	17,840.7	12,013.2	15,294.4	8,574.4	20,978.6	19,131.9	20,546.4	28,163.0	36,119.4	40,879.7	259,364.9
Total Teeland Substation Leaving the G&T System		41,983.6	75,553.5	49,137.7	33,823.6	32,108.2	15,695.9	39,640.0	27,982.3	28,329.4	43,618.9	72,028.3	85,121.5	545,022.9
Energy Leaving System														
Daves Creek Substation														
Daves Ck 115 BKR 952	S	5,065.5	4,793.5	5,100.6	4,820.2	5,109.7	4,746.3	5,234.3	5,390.4	4,807.1	4,584.2	4,105.1	4,991.1	58,748.0
Total Daves Creek Substation		5,065.5	4,793.5	5,100.6	4,820.2	5,109.7	4,746.3	5,234.3	5,390.4	4,807.1	4,584.2	4,105.1	4,991.1	58,748.0
Power Plant Station Service - Includes Generation Step-up (GSU) transformers losses														
Beluga Station Service	O	592.5	580.9	583.7	527.0	409.5	332.5	337.7	351.7	379.9	447.9	529.3	632.0	5,704.5
CLPP Station Service	O	151.4	162.1	107.0	102.8	104.7	135.3	130.0	84.5	92.1	146.1	133.9	122.0	1,471.9
Eklutna Station Service	O	30.3	26.4	28.9	23.5	22.0	19.0	22.0	21.0	20.0	21.0	20.0	21.0	275.1
Plant 1	O	152.1	381.2	204.5	143.2	288.3	158.4	202.8	131.2	221.6	825.6	316.2	183.0	3,208.0
Plant 2	O	437.8	397.0	428.8	391.0	382.6	368.2	380.1	352.8	350.5	425.8	515.9	541.0	4,971.5
Plant 2A	O	2,598.4	2,534.5	2,695.4	2,147.2	1,020.0	2,402.3	2,871.1	2,875.1	2,626.3	2,189.3	2,513.4	2,945.6	29,418.5
SPP Station Service	O	2,968.8	2,732.2	2,744.5	2,720.3	2,963.2	1,414.1	1,521.9	1,444.2	1,198.8	1,498.1	1,949.4	2,186.0	25,341.6
Total Station Service		6,931.2	6,814.2	6,792.9	6,055.0	5,190.4	4,829.7	5,465.6	5,260.4	4,889.2	5,553.8	5,978.2	6,630.6	70,391.2
South District - Distribution Substation Deliveries														
BEL_PH_1022	S	1,935.5	1,838.0	1,935.3	762.1	1,864.5	1,698.4	1,693.1	1,709.5	1,814.5	1,927.6	1,899.6	2,102.2	21,180.2
BEL_TV_6126	S	527.4	499.7	515.6	1,518.8	349.5	283.9	261.0	270.6	380.0	501.8	504.6	630.3	6,243.1
DC_352_452	S	573.7	540.6	655.1	622.4	640.2	662.8	658.5	623.2	647.9	613.3	575.9	638.6	7,452.1
GIRDWD_322	S	1,317.1	1,139.0	1,234.0	1,040.2	886.8	885.4	789.7	625.4	764.0	889.6	1,676.9	2,325.6	13,573.7
GIRDWD_422	S	1,174.6	1,078.6	1,164.1	973.7	818.1	720.3	730.9	865.3	779.5	908.7	611.8	1,011.4	10,837.0
HANE_T1	S	2,311.6	2,075.5	2,184.9	1,987.5	1,916.9	1,805.9	2,328.7	2,180.7	1,908.6	2,105.8	2,171.3	2,494.6	25,472.0
HOPE_322B	S	167.0	156.0	168.5	149.9	157.5	150.2	154.1	147.6	148.3	152.8	140.7	167.3	1,859.8
INSS_1232	S	8,031.6	7,099.6	7,516.4	6,796.1	6,432.8	6,012.5	6,510.2	7,260.7	7,334.1	8,343.3	7,550.0	8,547.0	87,434.2
INSS_1332	S	6,048.6	5,402.7	5,657.0	6,018.5	5,275.3	4,220.0	3,851.5	2,381.4	2,408.5	2,812.8	5,522.5	6,317.6	55,916.4
INSS_1532	S	5,461.7	4,880.5	5,243.6	5,545.1	5,055.0	4,423.7	4,863.1	5,732.7	5,415.6	5,980.4	5,076.8	5,570.1	63,248.3
INSS_332	S	351.6	292.9	326.3	304.5	278.1	244.0	232.3	244.6	256.3	301.6	310.6	327.2	3,470.0
INSS_732	S	9,612.7	12,553.3	8,282.9	6,104.7	5,128.0	3,924.9	3,528.8	4,326.8	4,927.3	4,506.6	4,708.4	5,226.5	72,830.6
INSS_832	S	6,552.8	(1.8)	4,934.3	4,447.7	5,840.6	7,462.3	8,073.5	7,100.2	7,114.8	8,249.7	8,251.4	9,191.3	77,216.9
INDIAN_212	S	228.1	202.4	212.8	193.2	188.7	181.0	184.6	185.2	190.5	216.0	193.9	239.1	2,415.4
PASS_162	S	1,461.8	1,291.5	1,405.3	1,302.6	1,264.6	1,106.3	1,185.6	1,504.5	1,424.9	1,514.4	1,391.7	1,524.2	16,377.2
PASS_262	S	2,917.9	2,607.4	2,838.4	2,694.6	2,788.2	2,824.2	3,015.4	3,099.9	2,740.0	2,827.8	2,828.1	2,903.8	34,085.6

Attachment I

Page 2 of 4

Chugach Electric Association, Inc.
 Monthly G&T Line Loss Calculation; U-99-106
 In Accordance with Section 7, April 12, 2002
 Tariff Advice Nos. 552-8 / 430-121

Values used in calculation not rounded; data formatted to show the nearest tenth of a MWh.

Measurement Point	Source ¹	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Total 2023
PORAGE_422	S	794.4	728.7	805.3	786.2	768.5	840.7	1,118.6	992.7	628.3	631.7	736.1	828.8	9,659.9
RR_XFMR_T1	S	16,168.6	14,391.1	15,162.1	13,581.5	12,986.5	12,325.8	12,515.3	13,804.9	12,514.8	14,430.2	15,166.0	16,967.6	170,014.3
RR_XFMR_T2	S	16,321.6	14,536.8	15,320.7	13,746.3	13,159.1	12,454.0	12,684.5	14,037.4	12,705.6	14,609.8	15,283.9	17,107.3	171,966.9
SUMMIT_LK	M	35.0	37.7	42.1	51.5	121.1	192.6	191.9	183.1	77.0	39.1	45.2	23.2	1,039.4
UVSS_1132	S	7,897.6	9,666.7	10,281.6	9,238.6	8,776.1	8,207.1	8,566.7	8,744.3	8,643.8	9,663.1	9,941.2	10,856.3	110,483.0
UVSS_1232	S	4,616.8	6,184.5	6,503.2	5,822.9	5,402.8	4,971.4	5,326.5	4,974.0	5,291.7	6,066.8	6,393.9	7,203.3	68,757.8
UVSS_1332	S	7,173.3	3,599.2	3,707.7	3,282.9	3,132.5	2,912.0	3,025.8	3,125.4	3,091.0	3,503.7	3,936.9	4,733.5	45,223.9
UVSS_1536	S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
FIW Station Service	S	(20.6)	(15.3)	(18.5)	(15.9)	(16.3)	(13.2)	(10.3)	(9.9)	(12.2)	(14.9)	(17.8)	(20.8)	(185.8)
Total South District - Distribution Substation		101,660.0	90,785.3	96,078.7	86,955.5	83,215.0	78,495.9	81,479.8	84,110.2	81,194.5	90,781.5	94,899.8	106,915.9	1,076,572.2
North District - Distribution Substation Deliveries														
Sub 6 12.47 Bus MW	S	5,601.6	4,974.9	5,093.3	4,709.8	4,485.5	4,616.0	4,377.3	4,636.7	4,473.0	5,221.6	4,757.4	5,290.1	58,237.1
Sub 6 34.5 Bus MW	S	4,130.2	3,768.4	4,118.2	3,871.8	4,081.1	4,067.2	4,263.8	4,360.1	3,851.4	4,012.6	3,926.7	4,169.0	48,620.4
Sub 7 12.47 Bus Station Megawatts MW	S	4,249.7	3,830.9	4,020.3	3,663.9	3,543.7	2,860.2	3,493.5	3,604.1	3,405.1	3,762.5	3,877.8	4,246.9	44,558.5
Sub 8 Main Bkr 14 MW	S	5,826.3	5,318.2	5,740.2	5,621.4	5,669.1	5,845.3	6,416.7	6,427.2	5,623.1	5,811.5	5,592.4	5,745.4	69,636.8
Sub 8 Main Bkr 4 Watts	S	4,122.0	3,674.0	3,640.9	3,677.4	3,397.5	3,183.6	3,376.8	3,512.4	3,298.5	3,635.6	3,844.2	4,274.1	43,637.1
Sub 10 12.47 Bus Station MegaWatts MW	S	5,619.2	5,055.0	5,556.1	5,153.0	4,584.6	4,314.8	4,498.0	4,601.7	4,322.6	4,542.2	3,921.6	4,065.7	56,234.5
Sub 12 SouthBus MW	S	12,879.7	10,616.3	14,236.8	13,367.5	10,497.9	15,945.7	16,730.2	20,121.6	18,734.4	14,955.5	17,630.6	20,735.0	186,451.1
Sub 12 NorthBus MW	S	(22,168.5)	(18,912.1)	(23,265.5)	(21,337.0)	(18,611.9)	(23,279.7)	(23,513.8)	(26,616.0)	(25,646.4)	(22,507.7)	(26,407.8)	(30,431.5)	(282,697.8)
Sub 12 Total Deliveries MW		9,288.9	8,295.8	9,028.7	7,969.5	8,114.0	7,334.0	6,783.6	6,494.4	6,911.9	7,552.2	8,777.2	9,696.5	96,246.7
Sub 14 115 Sub10Bus Watts	S	14,854.5	12,068.2	14,126.0	11,698.4	8,109.2	13,920.1	13,364.0	14,801.7	13,730.3	10,711.8	13,296.9	15,220.1	155,901.2
Sub 14 115 Anch Bus Watts	S	(5,738.1)	(4,469.1)	(2,865.4)	228.6	656.4	(849.3)	867.9	3,106.8	3,286.5	2,370.2	1,754.2	2,780.1	1,128.7
Sub 14 115 Plt2 Bus Watts	S	(15,575.2)	(13,368.1)	(17,474.6)	(16,908.2)	(14,561.5)	(18,692.2)	(20,140.7)	(24,022.9)	(22,585.6)	(19,028.3)	(21,574.3)	(25,164.3)	(229,095.8)
Sub 14 Total Deliveries MW		6,458.8	5,769.0	6,214.1	4,981.2	5,796.0	5,621.4	5,908.9	6,114.3	5,568.8	5,946.4	6,523.2	7,164.1	72,065.9
Sub 15 12.47 Bus Station MWatts MW	S	8,820.3	7,868.6	8,572.4	7,481.8	7,423.8	7,119.9	7,626.4	7,876.5	7,359.1	7,999.9	8,252.3	8,971.0	95,371.9
Sub 16 12.47 Bus MW	S	6,487.2	5,834.9	6,598.7	5,803.5	5,749.7	5,934.5	6,425.9	6,558.1	5,715.8	6,100.1	6,127.6	6,569.3	73,905.0
Sub 22 115 Sub 7 Bus Watts	S	2,842.8	328.6	123.8	1,980.1	4,871.6	(5,410.8)	(5,615.6)	(7,943.4)	(9,590.3)	(11,704.0)	(5,970.9)	(5,458.3)	(41,546.5)
Sub 22 115 Sub 16 Bus Watts	S	(5,938.5)	(5,940.3)	(5,542.9)	(1,511.2)	3,296.0	(7,999.8)	(9,393.4)	(7,896.0)	(10,256.7)	(9,703.0)	(6,996.9)	(6,857.9)	(74,740.4)
Sub 22 115 ITSS Bus Watts	S	(1,137.5)	1,744.6	1,119.9	(4,536.4)	(12,177.5)	9,366.0	10,664.8	11,385.5	16,069.0	17,409.6	9,016.2	8,132.0	67,056.3
Sub 22 Total Deliveries MW		4,233.2	3,867.1	4,299.2	4,067.5	4,010.0	4,044.5	4,344.3	4,453.8	3,777.9	3,997.4	3,951.6	4,184.2	49,230.6
Sub 20 12.47 Bus Station MegaWatts MW	S	3,416.7	3,051.8	3,308.1	3,388.3	2,791.7	2,658.3	2,801.0	2,823.4	2,768.8	3,140.8	2,870.8	3,225.5	36,245.2
Plant 1 Bkr 830 MW	S	1,723.9	1,579.6	1,683.2	1,527.5	1,527.0	1,549.3	1,650.0	1,674.7	1,472.1	2,395.5	3,971.0	4,337.8	25,091.6
Plant 1 Bkr 930 MW	S	1,861.6	1,705.1	1,862.5	1,775.8	1,945.5	1,879.2	2,018.4	1,981.3	1,462.9	1,736.7	1,788.2	1,880.5	21,897.7
Plant 1 Bkr 1130 MW	S	6,491.9	5,818.3	6,219.8	5,473.0	5,392.0	4,860.3	5,159.1	5,586.2	5,150.8	6,022.6	6,171.7	6,762.6	69,108.2
Plant 1 Bkr 1030 MW	S	880.9	802.5	864.3	799.7	781.1	789.1	817.1	831.4	743.0	63.7	(22.3)	(22.4)	7,328.0
Plant 1 Bkr 630 MW	S	485.3	453.7	451.6	420.8	526.6	495.4	394.0	(7.0)	150.4	470.7	431.2	478.6	4,751.3
Total North District - Distribution Substation		79,697.5	71,667.6	77,271.4	70,386.0	69,818.8	67,172.8	70,354.7	71,529.2	66,055.2	72,411.8	74,762.6	81,038.7	872,166.3
Total Energy Leaving System		254,398.7	274,549.7	250,695.7	218,864.7	208,820.2	184,173.6	214,698.9	220,935.6	213,648.2	242,062.1	267,949.9	301,263.8	2,852,061.1
Gross Energy Losses		3,968.6	4,319.5	3,111.0	2,614.5	2,113.0	2,701.4	2,817.2	2,312.8	2,531.3	3,018.4	3,260.9	3,091.7	35,860.2
Less Transformer Losses														
University (w/ Station Load)	O	161.2	161.2	161.2	161.2	161.2	161.2	161.2	161.2	161.2	161.2	161.2	161.2	1,934.8
Beluga	O	35.9	35.9	35.9	35.9	35.9	35.9	35.9	35.9	35.9	35.9	35.9	35.9	430.7
Indian	O	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	5.9	71.2
Girdwood	O	30.6	30.6	30.6	30.6	30.6	30.6	30.6	30.6	30.6	30.6	30.6	30.6	366.8
Portage	O	23.9	23.9	23.9	23.9	23.9	23.9	23.9	23.9	23.9	23.9	23.9	23.9	286.5
Hope	O	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	27.2
Summit Lake	O	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	25.1

Chugach Electric Association, Inc.
 Monthly G&T Line Loss Calculation; U-99-106
 In Accordance with Section 7, April 12, 2002
 Tariff Advice Nos. 552-8 / 430-121

Values used in calculation not rounded; data formatted to show the nearest tenth of a MWh.

Measurement Point	Source ¹	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Total 2023
Daves Creek	O	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	16.6	199.1
International	O	163.8	163.8	163.8	163.8	163.8	163.8	163.8	163.8	163.8	163.8	163.8	163.8	1,965.0
Sub 6 (Pending Study)	O	18.2	18.2	18.2	18.2	18.2	18.2	18.2	18.2	18.2	18.2	18.2	18.2	218.8
Sub 7 (Pending Study)	O	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sub 8	O	30.8	30.8	30.8	30.8	30.8	30.8	30.8	30.8	30.8	30.8	30.8	30.8	369.6
Sub 10 (Pending Study)	O	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sub 15	O	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	25.8	309.4
Sub 16 (Pending Study)	O	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sub 20	O	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	13.5	161.4
Total Transformer Losses		530.5	530.5	530.5	530.5	530.5	530.5	530.5	530.5	530.5	530.5	530.5	530.5	6,365.5
Net G&T Losses		3,438.1	3,789.0	2,580.5	2,084.0	1,582.5	2,171.0	2,286.7	1,782.4	2,000.8	2,487.9	2,730.5	2,561.3	29,494.7
Chugach Retail Distribution Losses														
Retail Receipts @ Trans SS	O	181,357.5	162,453.0	173,350.1	157,341.4	153,033.8	145,668.7	151,834.5	155,639.4	147,249.8	163,193.3	169,662.4	187,954.6	1,948,738.4
Less: Chugach House Pwr.	O	1,080.6	972.5	643.8	538.9	488.0	444.1	398.7	423.3	456.2	521.1	546.5	434.2	6,947.9
Net Receipts		180,276.9	161,480.5	172,706.3	156,802.6	152,545.8	145,224.6	151,435.8	155,216.1	146,793.6	162,672.2	169,115.8	187,520.4	1,941,790.6
Retail Sales @ Delivery	O	175,297.5	157,213.4	168,634.9	152,678.9	147,902.8	141,529.0	146,521.2	150,945.6	143,147.7	157,616.0	164,321.7	185,279.5	1,891,088.2
Losses		4,979.4	4,267.1	4,071.4	4,123.7	4,643.1	3,695.6	4,914.6	4,270.5	3,645.9	5,056.1	4,794.2	2,240.8	50,702.4
Add: 1/2 House Power		540.3	486.2	321.9	269.4	244.0	222.0	199.3	211.6	228.1	260.6	273.3	217.1	3,473.9
Adj. Retail Dist. Losses		5,519.7	4,753.4	4,393.3	4,393.1	4,887.0	3,917.7	5,114.0	4,482.2	3,874.0	5,316.7	5,067.4	2,457.9	54,176.3
At Delivery		3.149%	3.024%	2.605%	2.877%	3.304%	2.768%	3.490%	2.969%	2.706%	3.373%	3.084%	1.327%	2.865%
At Transmission Substation		3.062%	2.944%	2.544%	2.802%	3.204%	2.698%	3.377%	2.888%	2.639%	3.268%	2.996%	1.311%	2.790%
Adjustment of G&T Losses for House Power														
G&T Deliveries														
SES		5,098.3	4,822.1	5,131.1	4,851.2	5,139.7	4,774.2	5,259.3	5,412.2	4,833.7	4,617.1	4,131.6	5,019.0	59,089.5
RETAIL		181,357.5	162,453.0	173,350.1	157,341.4	153,033.8	145,668.7	151,834.5	155,639.4	147,249.8	163,193.3	169,662.4	187,954.6	1,948,738.4
Total Deliveries		186,455.7	167,275.0	178,481.2	162,192.7	158,173.5	150,442.9	157,093.8	161,051.6	152,083.4	167,810.4	173,794.0	192,973.6	2,007,827.9
Net G&T Losses		3,438.1	3,789.0	2,580.5	2,084.0	1,582.5	2,171.0	2,286.7	1,782.4	2,000.8	2,487.9	2,730.5	2,561.3	29,494.7
Add: 1/2 House Power		540.3	486.2	321.9	269.4	244.0	222.0	199.3	211.6	228.1	260.6	273.3	217.1	3,473.9
Adjusted G&T Losses		3,978.4	4,275.2	2,902.4	2,353.4	1,826.5	2,393.0	2,486.1	1,994.0	2,228.9	2,748.5	3,003.8	2,778.4	32,968.6
At Delivery		2.134%	2.556%	1.626%	1.451%	1.155%	1.591%	1.583%	1.238%	1.466%	1.638%	1.728%	1.440%	1.642%
At Generation		2.089%	2.492%	1.600%	1.430%	1.142%	1.566%	1.558%	1.223%	1.444%	1.611%	1.699%	1.419%	1.615%

¹Source of Data:

M: Metered data.

S: SCADA interval data.

O: Non-interval data.

Attachment II

Chugach Electric Association, Inc.
 Monthly G&T Line Loss Calculation; U-99-106
 In Accordance with Section 7, Black and Veatch G&T Line Loss Study
 Tariff Advice Nos. 552-8 / 430-121

2023 Transformer Loss Calculations - Chugach Retail System

Transformer	Size (MVA)	No Load Loss (MW)	Full Load Loss (MW)	Annual (MWh)	Load Factor	Transformer Losses at Load Factor (MW)	Annual Losses (MWh)
Beluga 1022	11.20	0.02200	0.10000	21,180.24	22%	0.027	233.54
Beluga 6126	10.00	0.02200	0.10000	6,243.14	7%	0.023	197.17
Daves Creek	10.00	0.02200	0.10000	7,452.09	9%	0.023	199.06
Girdwood	10.00	0.03100	0.14000	24,410.73	28%	0.042	366.79
Hope	1.25	0.00275	0.01250	1,859.82	17%	0.003	27.25
Indian	2.50	0.00770	0.03500	2,415.43	11%	0.008	71.18
Portage	10.00	0.03100	0.14000	9,659.87	11%	0.033	286.47
Summit	1.25	0.00275	0.01250	1,039.36	9%	0.003	25.08
UVSS	45.00	0.06500	0.53500	224,464.73	28%	0.108	949.29
UVSS Station Service Load	0.23	--	--	--	50%	0.113	985.50
International T1 ¹	75.00	0.10204	0.13187	206,598.93	31%	0.115	1,008.07
International T2 ¹	75.00	0.10204	0.13187	153,517.56	23%	0.109	956.94
Sub 6 12KV Xfmr (Pending Study) ²	16.80			58,237.06	40%	-	-
Sub 6 34.5KV Xfmr	28.00	0.02190	0.07830	48,620.36	20%	0.025	218.80
Sub 7 (Pending Study)	16.80			44,558.46	30%	-	-
Sub 8 BKR 4 Xfmr	16.80	0.01368	0.04788	43,637.11	30%	0.018	156.71
Sub 8 BKR 14 Xfmr	16.80	0.01344	0.04852	69,636.82	47%	0.024	212.90
Sub 10 (Pending Study)	16.80			56,234.45	38%	-	-
Sub 15	28.00	0.01686	0.12207	95,371.92	39%	0.035	309.36
Sub 16 (Pending Study)	16.80			73,905.02	50%	-	-
Sub 20	16.80	0.01480	0.05980	36,245.17	25%	0.018	161.42
Total							6,365.54

¹ MWh readings obtained from high side of the transformer. Excluded are MWh generated by IGT.

² Pending study to provide transformer data per IEEE C57 Standard testing